

Appendix A: High Risk Activities

No work that puts the employee at high risk for injury is to be conducted when working alone including work that involves any of the following:

- Confined space entry. [O. Reg 851, PRO 1990, Sec. 69 (f)].
- An installation, equipment or conduction operating at a normal voltage of 300 volts or more, except while testing equipment or troubleshooting. An individual, who is able to recognize the hazards and perform rescue operations, including artificial respiration, will be available and able to see the worker performing the work. [O. Reg 851, Sec. 42.1]
- Electrical systems rated at more than 750 volts. [O. Reg 851, Sec. 42.2]
- Machine and power tools that can cause injury. [CSA Standard Z94.4-93, Sec. 9.3.3, 9.3.4]
- A portable ladder exceeding six meters or 18 feet in length and is not securely fastened or works with a ladder that is likely to be endangered by traffic. [O. Reg 851, Sec. 73]
- Quick-acting acutely toxic material. [CSA Standard Z94.4-93, Sec. 9.3.3, 9.3.4]
- The use of supplied air respiratory equipment or self-contained breathing apparatus. [CSA Standard Z94.4-93, Sec. 9.3.3, 9.3.4]
- Use of a vehicle, or similar equipment near a live power line where it is possible for any part of the equipment or its load to make contact with the live power line. [O. Reg 851, Sec. 60]
- Use of a vehicle, or similar equipment where the operator does not have full view of the intended path of travel. [O. Reg 851, Sec. 56]
- Tasks which are based on the risk assessment conducted by the Supervisor in consultation with the employee, the Joint Health and Safety Committee worker representative(s) and the Health and Safety Coordinator are deemed to require more than one person.